

Certificate of Suitability

Certificate No.: SAA191131

Certificate Holder: ShenZhen Lux Power Technology Co., Ltd

Room 403, 4th Floor, Building 63,

Zhongwu New Industrial Park, Hangcheng Street,

Baoan District, Shenzhen, Guangdong Province

P.R. China

Class Description: Non-Declared

Product Description: AC Storage Inverter Brand Name: LUXPOWER TEK

Model No.: LXP 3600ACS

Markings: Input: 230V~ 50/60Hz 3600W, Max 16A

EPS: 230V~ 50/60Hz 3600VA

Battery: 40-60Vdc, Lead-acid/Lithium Max charge and discharge current: 70A Max charge and discharge power: 3600W

-25°C to +60°C, Class I, IP65

Standard: AS 62040.1.1:2003

AS/NZS 4777.2:2015

Conditions: Ni

Certification Mark: SAA191131 or RCM

Date First Registered: 8 May 2019
Date of Expiry: 8 May 2024

R. A. Nills

For and on Behalf of SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to: www.saaapprovals.com.au





Issued: 08-05-19 191131/1