



Fair
Trading

File Ref: CS11096/2
Contact: Admin Clerk
Telephone: 02 9895 0722

Ms Lydia Zhong
Shenzhen Lux Power Technology Co., Ltd.
C/- Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch
No.96, Houjie Section, Guantai Rd, Houjie Town
Dongguan City, Guangdong
China 523942

Dear Sir/Madam

VARIATION TO CERTIFICATE OF SUITABILITY: CS11096N

Inverter

Please find enclosed an addendum to the certificate as sought in your application.

Yours faithfully,

2 August 2022

For Secretary, Department of Customer Service



Fair
Trading

Ref: CS11096/2

ADDENDUM TO CERTIFICATE OF SUITABILITY: CS11096N Particulars of Modification(s)

Hybrid Inverter Model No. LXP-3KHybrid-NS now rated as below: -
Rated Output AC Current: 13A, Max. Output AC Current: 15A, Rated Output AC Power (Grid): 3000W, Max./Rated Output Apparent Power (Grid): 3000VA, UPS Rated Output AC Power; 3000VA, UPS Max. Output AC Power (with PV): 3000VA, UPS Max. Output AC Power (without PV): 3000VA

Hybrid Inverter Model No. LXP-4KHybrid-NS now rated as below: -
Rated Output AC Current: 17.4A, Max. Output AC Current: 20A, Rated Output AC Power (Grid): 4000W, Max./Rated Output Apparent Power (Grid): 4000VA, UPS Rated Output AC Power; 3000VA, UPS Max. Output AC Power (with PV): 4000VA, UPS Max. Output AC Power (without PV): 3600VA

Hybrid Inverter Model No. LXP-4.6KHybrid-NS now rated as below: -
Rated Output AC Current: 20A, Max. Output AC Current: 25A, Rated Output AC Power (Grid): 4600W, Max./Rated Output Apparent Power (Grid): 4600VA, UPS Rated Output AC Power; 3000VA, UPS Max. Output AC Power (with PV): 4600VA, UPS Max. Output AC Power (without PV): 3600VA

Hybrid Inverter Model No. LXP-5KHybrid-NS now rated as below: -
Rated Output AC Current: 21.7A, Max. Output AC Current: 25A, Rated Output AC Power (Grid): 5000W, Max./Rated Output Apparent Power (Grid): 5000VA, UPS Rated Output AC Power; 3000VA, UPS Max. Output AC Power (with PV): 5000VA, UPS Max. Output AC Power (without PV): 3600VA

This certificate will expire on 14/06/2027

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:

2 August 2022

For Secretary, Department of Customer Service