



TL-395

Test Report issued under the responsibility of:



TEST REPORT
IEC 61727
Photovoltaic (PV) systems –
Characteristics of the utility interface

Report Number..... : 260302136GZU-001

Date of issue..... : 12 Mar 2026

Total number of pages 25 Pages

Name of Testing Laboratory preparing the Report Intertek Testing Services Shenzhen Ltd. Guangzhou Branch
Room101/301/401/102/202/302/402/502/602/702/802, No. 7-2, Caipin Road, Huangpu District, Guangzhou, Guangdong, China.

Applicant's name : Shenzhen Lux Power Technology Co., Ltd.

Address : C501, Building A, Donghua Industrial Park, 5003 Bao'an Avenue, Sanwei Community, Hangcheng Street, Bao'an District, Shenzhen, 518126, China.

Test specification:

Standard : IEC 61727:2004

Test procedure : Type approval

Non-standard test method : N/A

Test Report Form No. : IEC61727B

Test Report Form(s) Originator : TÜV SÜD Product Service GmbH

Master TRF : Dated 2017-11-03

Copyright © 2017 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.



General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description . :	Smart PCS																																																																																																														
Trade Mark	Lux Power																																																																																																														
Manufacturer.....	Same as Applicant																																																																																																														
Model/Type reference . :	SNA PRO-EU 3K, SNA PRO-EU 4K, SNA PRO-EU 5K , SNA PRO-EU 6K, SNA PRO-EU 6.5K																																																																																																														
Ratings	<table border="1"> <thead> <tr> <th>Model</th> <th>SNA PRO-EU 3K</th> <th>SNA PRO-EU 4K</th> <th>SNA PRO-EU 5K</th> <th>SNA PRO-EU 6K</th> <th>SNA PRO-EU 6.5K</th> </tr> </thead> <tbody> <tr> <td colspan="7">Input (PV)</td> </tr> <tr> <td>Max. input voltage</td> <td colspan="5">500 Vd.c.</td> </tr> <tr> <td>MPPT voltage range</td> <td colspan="5">80-400 Vd.c.</td> </tr> <tr> <td>Max. short-circuit current</td> <td colspan="5">25/25 Ad.c.</td> </tr> <tr> <td>Max. input current per MPPT</td> <td colspan="5">20/20 Ad.c.</td> </tr> <tr> <td colspan="7">Input(Battery)</td> </tr> <tr> <td>Battery type</td> <td colspan="5">Lithium-ion/Lead-Acid</td> </tr> <tr> <td>Battery voltage range</td> <td colspan="5">38.4-60 Vd.c.</td> </tr> <tr> <td>Max. charging current</td> <td>70 Ad.c.</td> <td>90 Ad.c.</td> <td>110 Ad.c.</td> <td>135 Ad.c.</td> <td>135 Ad.c.</td> </tr> <tr> <td>Max. charging current power</td> <td>3000 W</td> <td>4000 W</td> <td>5000 W</td> <td>6000 W</td> <td>6500 W</td> </tr> <tr> <td colspan="7">Output/Input (On Grid)</td> </tr> <tr> <td>Rated output power</td> <td>3000 W</td> <td>4000 W</td> <td>5000 W</td> <td>6000 W</td> <td>6500 W</td> </tr> <tr> <td>Rated input power</td> <td>6000 W</td> <td>8000 W</td> <td>8000 W</td> <td>9000 W</td> <td>9000 W</td> </tr> <tr> <td>Max. apparent power</td> <td>3000 VA</td> <td>4000 VA</td> <td>5000 VA</td> <td>6000 VA</td> <td>6500 VA</td> </tr> <tr> <td>Rated output voltage</td> <td colspan="5">220/230 Va.c., L/N/PE</td> </tr> <tr> <td>Max. output</td> <td>13 Aa.c.</td> <td>17.5</td> <td>22 Aa.c.</td> <td>26.5</td> <td>28.2</td> </tr> </tbody> </table>						Model	SNA PRO-EU 3K	SNA PRO-EU 4K	SNA PRO-EU 5K	SNA PRO-EU 6K	SNA PRO-EU 6.5K	Input (PV)							Max. input voltage	500 Vd.c.					MPPT voltage range	80-400 Vd.c.					Max. short-circuit current	25/25 Ad.c.					Max. input current per MPPT	20/20 Ad.c.					Input(Battery)							Battery type	Lithium-ion/Lead-Acid					Battery voltage range	38.4-60 Vd.c.					Max. charging current	70 Ad.c.	90 Ad.c.	110 Ad.c.	135 Ad.c.	135 Ad.c.	Max. charging current power	3000 W	4000 W	5000 W	6000 W	6500 W	Output/Input (On Grid)							Rated output power	3000 W	4000 W	5000 W	6000 W	6500 W	Rated input power	6000 W	8000 W	8000 W	9000 W	9000 W	Max. apparent power	3000 VA	4000 VA	5000 VA	6000 VA	6500 VA	Rated output voltage	220/230 Va.c., L/N/PE					Max. output	13 Aa.c.	17.5	22 Aa.c.	26.5	28.2
Model	SNA PRO-EU 3K	SNA PRO-EU 4K	SNA PRO-EU 5K	SNA PRO-EU 6K	SNA PRO-EU 6.5K																																																																																																										
Input (PV)																																																																																																															
Max. input voltage	500 Vd.c.																																																																																																														
MPPT voltage range	80-400 Vd.c.																																																																																																														
Max. short-circuit current	25/25 Ad.c.																																																																																																														
Max. input current per MPPT	20/20 Ad.c.																																																																																																														
Input(Battery)																																																																																																															
Battery type	Lithium-ion/Lead-Acid																																																																																																														
Battery voltage range	38.4-60 Vd.c.																																																																																																														
Max. charging current	70 Ad.c.	90 Ad.c.	110 Ad.c.	135 Ad.c.	135 Ad.c.																																																																																																										
Max. charging current power	3000 W	4000 W	5000 W	6000 W	6500 W																																																																																																										
Output/Input (On Grid)																																																																																																															
Rated output power	3000 W	4000 W	5000 W	6000 W	6500 W																																																																																																										
Rated input power	6000 W	8000 W	8000 W	9000 W	9000 W																																																																																																										
Max. apparent power	3000 VA	4000 VA	5000 VA	6000 VA	6500 VA																																																																																																										
Rated output voltage	220/230 Va.c., L/N/PE																																																																																																														
Max. output	13 Aa.c.	17.5	22 Aa.c.	26.5	28.2																																																																																																										


current		Aa.c.		Aa.c.	Aa.c.
Max. input current	26 Aa.c.	35 Aa.c.	35 Aa.c.	39.1 Aa.c.	39.1 Aa.c.
Rated AC grid frequency	50/60 Hz				
Adjustable power factor	0.9 leading-0.9 lagging				
Backup parameter (AC)					
Rated output power	2000 W	2000 W	2000 W	3000 W	3000 W
Max. output current	8.6 Aa.c.	8.6 Aa.c.	8.6 Aa.c.	13 Aa.c.	13 Aa.c.
Rated output voltage	220/230 Va.c., L/N/PE				
AC frequency	50/60 Hz				
General Data					
Safety level	Class I				
Degree of protection	IP66				
Operating temperature range	-25~60 °C (derating at 45°C)				
FW Version	V1.0				

Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/>	Testing Laboratory:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch
Testing location/ address.....:		Room101/301/401/102/202/302/402/502/602/702/802, No. 7-2, Caipin Road, Huangpu District, Guangzhou, Guangdong, China.
<input type="checkbox"/>	Associated CB Testing Laboratory:	N/A
Testing location/ address.....:		N/A
Tested by (name, function, signature).....:		Charlie Yang Engineer 
Approved by (name, function, signature)....:		Jason Fu Supervisor 
<hr/>		
<input type="checkbox"/>	Testing procedure: TMP/CTF Stage 1:	N/A
Testing location/ address.....:		N/A
Tested by (name, function, signature).....:		N/A
Approved by (name, function, signature)....:		N/A
<hr/>		
<input type="checkbox"/>	Testing procedure: WMT/CTF Stage 2:	N/A
Testing location/ address.....:		N/A
Tested by (name + signature)		N/A
Witnessed by (name, function, signature) ..:		N/A
Approved by (name, function, signature)....:		N/A
<hr/>		
<input type="checkbox"/>	Testing procedure: SMT/CTF Stage 3 or 4:	N/A
Testing location/ address.....:		N/A
Tested by (name, function, signature).....:		N/A
Witnessed by (name, function, signature) ..:		N/A
Approved by (name, function, signature)....:		N/A
Supervised by (name, function, signature) :		N/A
<hr/>		

List of Attachments (including a total number of pages in each attachment): Appendix 1: photos (2 pages)	
Summary of testing:	
Tests performed (name of test and test clause): All applicable tests	Testing location: Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Room 101/301/401/102/202/302/402/502/602/702/ 802, No. 7-2, Caipin Road, Huangpu District, Guangzhou, Guangdong, China.
Summary of compliance with National Differences: List of countries addressed N/A	
<input checked="" type="checkbox"/> The product fulfils the requirements of IEC 61727:2004	

Copy of marking plate:

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.

LU X POWER^{TEK}	
Energy Storage Inverter	
Model Name	SNA PRO-EU 6.5K
PV Input	
Max. PV Input voltage	500d.c.V
MPPT voltage range	80-400d.c.V
Number of MPPT Inputs	2
Inputs per MPPT	1/1
Max. PV short current(Input A/B)	25d.c.A/25d.c.A
Max. PV current(Input A/B)	20d.c.A/20d.c.A
Max. PV power	12000W(6000W+6000W)
AC Input	
Nominal AC voltage, Frequency	230.a.c.V,50Hz/60Hz
Max. GRID Input	39.1a.c.A,9000W
Max. GEN Input	32a.c.A,7370W
Max. AC charging power to battery	6500W
AC Output(Back-up)	
Nominal voltage,current	230a.c.V/28.2a.c.A
Frequency	50Hz/60Hz
Nominal output power	6500W(L-N)
Output power factor	0.75~0.99
Battery	
Battery type	Lithium-ion/Lead-Acid
Battery voltage range	38.4d.c.V-60d.c.V
Nominal voltage	48d.c.V
Max. charge and discharge current	135d.c.A/140d.c.A
Max. charge and discharge power	6500W/6500W
Environment	
Altitude	<6561ft
Ingress protection rating	IP66
Protective class	I
Operating environment temperature	0-45°C
Display	LCD+LED
Communication	RS485/WIFI/CAN
	
Shenzhen Lux Power Technology Co., Ltd C501, Building A, Donghua Industrial Park, 5003 Bao'an Avenue, Sanwei Community, Hangcheng Street, Bao'an District, Shenzhen, 518126, China.	

Note:


1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation.
3. Other models same as above except rating parameters.

Test item particulars :	
Classification of installation and use : Fixed and outdoor used	
Supply Connection : Permanent connection	
Possible test case verdicts:	
- test case does not apply to the test object: N/A	
- test object does meet the requirement.....: P (Pass)	
- test object does not meet the requirement.....: F (Fail)	
Testing:	
Date of receipt of test item: 02 Mar 2026	
Date (s) of performance of tests: 03 Mar 2026 – 10 Mar 2026	
General remarks:	
<p>"(See Enclosure #)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report. Throughout this report a <input type="checkbox"/> comma / <input checked="" type="checkbox"/> point is used as the decimal separator.</p> <p>Determination of the test conclusion is based on IEC Guide 115 in consideration of measurement uncertainty.</p> <p>This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.</p> <p>The test report only allows to be revised only within the report defined retention period unless standard or regulation was withdrawn or invalid.</p>	
Manufacturer's Declaration per sub-clause 4.2.5 of IEC 61727B:	
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> Not applicable
When differences exist; they shall be identified in the General product information section.	
Name and address of factory (ies): Huizhou Jingchuangyuan Technology Co., Ltd No.86, Hechang 7th Road (W), Zhongkai High-tech Zone, Huizhou, Guangdong, China	

General product information:

- 1) The Solar Inverter converts DC voltage into AC voltage.
- 2) The enclosure assembly was secured by screws.
- 3) Dusty conditions on the unit may impair the performance of this inverter.
- 4) It is manufactured to be mounted on a wall and its degree of protection is IP65.
- 5) The ambient temperature should be between -10°C and +50°C to ensure optimal operation.
- 6) All models have the similar constructions, circuit diagram and PCB layout except model name and output power. (See below table for details) Unless otherwise stated, all tests were performed on model SNA PRO.EU 6.5K, which means the typical model.

The topology diagram as following:



The product was tested on:

The Software version: CHAA-xx02

The Hardware version: E

IEC61727			
Cl.	Requirement - Test	Result	Verdict
4	UTILITY COMPATIBILITY		P
	The quality of power provided by the PV system for the on-site AC loads and for power delivered to the utility is governed by practices and standards on voltage, flicker, frequency, harmonics and power factor.		P
	Deviation from these standards represents out-of-bounds conditions and may require the PV system to sense the deviation and properly disconnect from the utility system.		P
4.1	Voltage, current and frequency		P
	The PV system AC voltage, current and frequency are compatible with the utility system.		P
4.2	Normal voltage operating range		P
	Utility-interconnected PV systems do not normally regulate voltage, they inject current into the utility. Therefore, the voltage operating range for PV inverters is selected as a protection function that responds to abnormal utility conditions, not as a voltage regulation function.		P
4.3	Flicker		P
	The operation of the PV system is not cause voltage flicker in excess of limits stated in the relevant sections of IEC 61000-3-3 for systems less than 16 A or IEC 61000-3-5 for systems with current of 16 A and above.		P
4.4	DC injection		P
	The PV system is not inject DC current greater than 1 % of the rated inverter output current, into the utility AC interface under any operating condition.	(See appended table)	P
4.5	Normal frequency operating range		P
	The PV system operates in synchronism with the utility system, and within the frequency trip limits defined in 5.2.2.		P
4.6	Harmonics and waveform distortion		P
	Total harmonic current distortion is less than 5 % at rated inverter output. Each individual harmonic is limited to the percentages listed in Table 1.	(See appended table)	P
	Even harmonics in these ranges is less than 25 % of the lower odd harmonic limits listed.		P

IEC61727																					
Cl.	Requirement - Test	Result	Verdict																		
	<table border="1"> <thead> <tr> <th colspan="2">Table 1 – Current distortion limits</th> </tr> <tr> <th>Odd harmonics</th> <th>Distortion limit</th> </tr> </thead> <tbody> <tr> <td>3rd through 9th</td> <td>Less than 4,0 %</td> </tr> <tr> <td>11th through 15th</td> <td>Less than 2,0 %</td> </tr> <tr> <td>17th through 21st</td> <td>Less than 1,5 %</td> </tr> <tr> <td>23rd through 33rd</td> <td>Less than 0,6 %</td> </tr> <tr> <th>Even harmonics</th> <th>Distortion limit</th> </tr> <tr> <td>2rd through 8th</td> <td>Less than 1,0 %</td> </tr> <tr> <td>10th through 32nd</td> <td>Less than 0,5 %</td> </tr> </tbody> </table>		Table 1 – Current distortion limits		Odd harmonics	Distortion limit	3 rd through 9 th	Less than 4,0 %	11 th through 15 th	Less than 2,0 %	17 th through 21 st	Less than 1,5 %	23 rd through 33 rd	Less than 0,6 %	Even harmonics	Distortion limit	2 rd through 8 th	Less than 1,0 %	10 th through 32 nd	Less than 0,5 %	P
Table 1 – Current distortion limits																					
Odd harmonics	Distortion limit																				
3 rd through 9 th	Less than 4,0 %																				
11 th through 15 th	Less than 2,0 %																				
17 th through 21 st	Less than 1,5 %																				
23 rd through 33 rd	Less than 0,6 %																				
Even harmonics	Distortion limit																				
2 rd through 8 th	Less than 1,0 %																				
10 th through 32 nd	Less than 0,5 %																				
4.7	The PV system has a lagging power factor greater than 0,9 when the output is greater than 50 % of the rated inverter output power.		P																		
5	PERSONNEL SAFETY AND EQUIPMENT PROTECTION		P																		
	This Clause provides information and considerations for the safe and proper operation of the utility-connected PV systems.		P																		
5.1	Loss of utility voltage		P																		
	To prevent islanding, a utility connected PV system ceases to energize the utility system from a de-energized distribution line irrespective of connected loads or other generators within specified time limits.	Complied with IEC 62116, See the separate report for reference Report No.:260302136GZU-002	P																		
	A utility distribution line can become de-energized for several reasons. For example, a substation breaker opening due to fault conditions or the distribution line switched out during maintenance.		P																		
5.2	Over/under voltage and frequency		P																		
	The abnormal utility conditions of concern are voltage and frequency excursions above or below the values stated in this Clause, and the complete disconnection of the utility, presenting the potential for a distributed resource island.		P																		
5.2.1	Over/under voltage		P																		
	When the interface voltage deviates outside the conditions specified in Table 2, the photovoltaic system ceases to energize the utility distribution system. This applies to any phase of a multiphase system.	(See appended table)	P																		

IEC61727															
Cl.	Requirement - Test	Result	Verdict												
	<p align="center">Table 2 – Response to abnormal voltages</p> <table border="1"> <thead> <tr> <th>Voltage (at point of utility connection)</th> <th>Maximum trip time*</th> </tr> </thead> <tbody> <tr> <td>$V < 0,5 \times V_{nominal}$</td> <td>0,1 s</td> </tr> <tr> <td>$50 \% \leq V < 85 \%$</td> <td>2,0 s</td> </tr> <tr> <td>$85 \% \leq V \leq 110 \%$</td> <td>Continuous operation</td> </tr> <tr> <td>$110 \% < V < 135 \%$</td> <td>2,0 s</td> </tr> <tr> <td>$135 \% \leq V$</td> <td>0,05 s</td> </tr> </tbody> </table> <p>* Trip time refers to the time between the abnormal condition occurring and the inverter ceasing to energize the utility line. The PV system control circuits shall actually remain connected to the utility to allow sensing of utility electrical conditions for use by the "reconnect" feature.</p>	Voltage (at point of utility connection)	Maximum trip time*	$V < 0,5 \times V_{nominal}$	0,1 s	$50 \% \leq V < 85 \%$	2,0 s	$85 \% \leq V \leq 110 \%$	Continuous operation	$110 \% < V < 135 \%$	2,0 s	$135 \% \leq V$	0,05 s		P
Voltage (at point of utility connection)	Maximum trip time*														
$V < 0,5 \times V_{nominal}$	0,1 s														
$50 \% \leq V < 85 \%$	2,0 s														
$85 \% \leq V \leq 110 \%$	Continuous operation														
$110 \% < V < 135 \%$	2,0 s														
$135 \% \leq V$	0,05 s														
5.2.2	Over/under frequency		P												
	When the utility frequency deviates outside the specified conditions the photovoltaic system ceases to energize the utility line. The unit does not have to cease to energize if the frequency returns to the normal utility continuous operation condition within the specified trip time.	(See appended table)	P												
	When the utility frequency is outside the range of ± 1 Hz, the system ceases to energize the utility line within 0,2 s. The purpose of the allowed range and time delay is to allow continued operation for short-term disturbances and to avoid excessive nuisance tripping in weak-utility system conditions.		P												
5.3	Islanding protection		P												
	The PV system must cease to energize the utility line within 2 s of loss of utility.		P												
5.4	Response to utility recovery		P												
	Following an out-of-range utility condition that has caused the photovoltaic system to cease energizing, the photovoltaic system is not energize the utility line for 20 s to 5 min after the utility service voltage and frequency have recovered to within the specified ranges.	(See appended table)	P												
5.5	Earthing		P												
	The utility interface equipment is earthed/grounded in accordance with IEC 60364-7-712.		P												
5.6	Short circuit protection		N/A												
	The photovoltaic system has short-circuit protection in accordance with IEC 60364-7-712.	Should consider in the end use	N/A												
5.7	Isolation and switching		N/A												
	A method of isolation and switching is provided in accordance with IEC 60364-7-712.	Should consider in the end use	N/A												

4.3	TABLE: Flicker				P
Model: SNA PRO-EU 3K					
	Starting	Stopping	Running		
Limit	4%	4%	Pst = 1.0	Plt = 0.65	
Test value L1-N	0.001	0.001	0.094	0.056	
Model: SNA PRO-EU 3K					
	Starting	Stopping	Running		
Limit	4%	4%	Pst = 1.0	Plt = 0.65	
Test value L1-N	0.001	0.001	0.017	0.017	
Supplementary information: Test with 220 Va.c.					

4.3	TABLE: Flicker				P
Model: SNA PRO-EU 6.5K					
	Starting	Stopping	Running		
Limit	4%	4%	Pst = 1.0	Plt = 0.65	
Test value L1-N	0.001	0.001	0.082	0.056	
Model: SNA PRO-EU 6.5K					
	Starting	Stopping	Running		
Limit	4%	4%	Pst = 1.0	Plt = 0.65	
Test value L1-N	0.001	0.001	0.017	0.017	
Supplementary information: Test with 230 Va.c.					

4.4	TABLE: Direct current injection								P
Rated output current (A)	Ratio of rated output power (VA)	Measured DC output current between terminals						Isolated transformer ? (Yes/No)	Limit (mA)
		L1-L2 (mA)	L1-L3 (mA)	L2-L3 (mA)	L1-N (mA)	L2-N (mA)	L3-N (mA)		
Model: SNA PRO-EU 3K									
13.64	33%	--	--	--	64	--	--	No	136.4
13.64	66%	--	--	--	58	--	--	No	136.4
13.64	100%	--	--	--	72	--	--	No	136.4
Model: SNA PRO-EU 6.5K									
29.55	33%	--	--	--	141	--	--	No	295.5
29.55	66%	--	--	--	161	--	--	No	295.5

29.55	100%	--	--	--	155	--	--	No	295.5
Supplementary information: Test with 220 Va.c.									

4.4 TABLE: Direct current injection									P
Rated output current (A)	Ratio of rated output power (VA)	Measured DC output current between terminals						Isolated transformer ? (Yes/No)	Limit (mA)
		L1-L2 (mA)	L1-L3 (mA)	L2-L3 (mA)	L1-N (mA)	L2-N (mA)	L3-N (mA)		
Model: SNA PRO-EU 3K									
13.04	33%	--	--	--	35	--	--	No	130.4
13.04	66%	--	--	--	33	--	--	No	130.4
13.04	100%	--	--	--	48	--	--	No	130.4
Model: SNA PRO-EU 6.5K									
28.26	33%	--	--	--	137	--	--	No	282.6
28.26	66%	--	--	--	152	--	--	No	282.6
28.26	100%	--	--	--	151	--	--	No	282.6
Supplementary information: Test with 230 Va.c.									

4.6 TABLE: Harmonics and waveform distortion							P
Harmonic	fundamental L1 (A)	% of fundamental	fundamental L2 (A)	% of fundamental	fundamental L3 (A)	% of fundamental	Harmonic Current Limits (%)
Model: SNA PRO-EU 3K							
02	0.024	0.175%	--	--	--	--	1.0%
03	0.309	2.263%	--	--	--	--	4.0%
04	0.026	0.194%	--	--	--	--	1.0%
05	0.072	0.527%	--	--	--	--	4.0%
06	0.012	0.086%	--	--	--	--	1.0%
07	0.071	0.523%	--	--	--	--	4.0%
08	0.008	0.058%	--	--	--	--	1.0%
09	0.062	0.455%	--	--	--	--	4.0%
10	0.010	0.077%	--	--	--	--	0.5%
11	0.048	0.351%	--	--	--	--	2.0%
12	0.005	0.035%	--	--	--	--	0.5%
13	0.064	0.472%	--	--	--	--	2.0%
14	0.006	0.045%	--	--	--	--	0.5%

15	0.042	0.304%	--	--	--	--	2.0%
16	0.006	0.047%	--	--	--	--	0.5%
17	0.030	0.216%	--	--	--	--	1.5%
18	0.003	0.023%	--	--	--	--	0.5%
19	0.031	0.228%	--	--	--	--	1.5%
20	0.007	0.054%	--	--	--	--	0.5%
21	0.036	0.263%	--	--	--	--	1.5%
22	0.004	0.032%	--	--	--	--	0.5%
23	0.019	0.141%	--	--	--	--	0.6%
24	0.003	0.022%	--	--	--	--	0.5%
25	0.017	0.128%	--	--	--	--	0.6%
26	0.005	0.034%	--	--	--	--	0.5%
27	0.023	0.166%	--	--	--	--	0.6%
28	0.011	0.081%	--	--	--	--	0.5%
29	0.021	0.152%	--	--	--	--	0.6%
30	0.026	0.192%	--	--	--	--	0.5%
31	0.023	0.170%	--	--	--	--	0.6%
32	0.012	0.090%	--	--	--	--	0.5%
33	0.011	0.080%	--	--	--	--	0.6%
THD	2.602%		--		--		5%

Model: SNA PRO-EU 6.5K

Harmonic	fundamental L1 (A)	% of fundamental	fundamental L2 (A)	% of fundamental	fundamental L3 (A)	% of fundamental	Harmonic Current Limits (%)
02	0.030	0.229%	--	--	--	--	1.0%
03	0.302	2.316%	--	--	--	--	4.0%
04	0.026	0.202%	--	--	--	--	1.0%
05	0.070	0.539%	--	--	--	--	4.0%
06	0.016	0.123%	--	--	--	--	1.0%
07	0.048	0.371%	--	--	--	--	4.0%
08	0.005	0.037%	--	--	--	--	1.0%
09	0.078	0.600%	--	--	--	--	4.0%
10	0.014	0.107%	--	--	--	--	0.5%
11	0.040	0.304%	--	--	--	--	2.0%

12	0.005	0.038%	--	--	--	--	0.5%
13	0.043	0.332%	--	--	--	--	2.0%
14	0.003	0.022%	--	--	--	--	0.5%
15	0.041	0.316%	--	--	--	--	2.0%
16	0.009	0.068%	--	--	--	--	0.5%
17	0.041	0.316%	--	--	--	--	1.5%
18	0.005	0.037%	--	--	--	--	0.5%
19	0.030	0.230%	--	--	--	--	1.5%
20	0.004	0.032%	--	--	--	--	0.5%
21	0.023	0.178%	--	--	--	--	1.5%
22	0.009	0.069%	--	--	--	--	0.5%
23	0.031	0.236%	--	--	--	--	0.6%
24	0.007	0.052%	--	--	--	--	0.5%
25	0.021	0.162%	--	--	--	--	0.6%
26	0.005	0.038%	--	--	--	--	0.5%
27	0.015	0.117%	--	--	--	--	0.6%
28	0.011	0.085%	--	--	--	--	0.5%
29	0.023	0.180%	--	--	--	--	0.6%
30	0.024	0.183%	--	--	--	--	0.5%
31	0.015	0.117%	--	--	--	--	0.6%
32	0.013	0.099%	--	--	--	--	0.5%
33	0.009	0.067%	--	--	--	--	0.6%
THD	2.645%		--		--		5%

Supplementary information: Test with 220 Va.c.

4.6	TABLE: Harmonics and waveform distortion						P
Model: SNA PRO-EU 3K							
Harmonic	fundamental L1 (A)	% of fundamental	fundamental L2 (A)	% of fundamental	fundamental L3 (A)	% of fundamental	Harmonic Current Limits (%)
02	0.017	0.059%	--	--	--	--	1.0%
03	1.177	3.985%	--	--	--	--	4.0%
04	0.014	0.048%	--	--	--	--	1.0%
05	0.164	0.555%	--	--	--	--	4.0%

06	0.038	0.127%	--	--	--	--	1.0%
07	0.019	0.066%	--	--	--	--	4.0%
08	0.020	0.069%	--	--	--	--	1.0%
09	0.217	0.734%	--	--	--	--	4.0%
10	0.010	0.035%	--	--	--	--	0.5%
11	0.099	0.335%	--	--	--	--	2.0%
12	0.003	0.010%	--	--	--	--	0.5%
13	0.148	0.500%	--	--	--	--	2.0%
14	0.007	0.024%	--	--	--	--	0.5%
15	0.097	0.329%	--	--	--	--	2.0%
16	0.004	0.012%	--	--	--	--	0.5%
17	0.062	0.211%	--	--	--	--	1.5%
18	0.004	0.014%	--	--	--	--	0.5%
19	0.075	0.254%	--	--	--	--	1.5%
20	0.004	0.012%	--	--	--	--	0.5%
21	0.055	0.185%	--	--	--	--	1.5%
22	0.005	0.018%	--	--	--	--	0.5%
23	0.017	0.057%	--	--	--	--	0.6%
24	0.006	0.020%	--	--	--	--	0.5%
25	0.044	0.149%	--	--	--	--	0.6%
26	0.006	0.019%	--	--	--	--	0.5%
27	0.048	0.162%	--	--	--	--	0.6%
28	0.014	0.047%	--	--	--	--	0.5%
29	0.024	0.081%	--	--	--	--	0.6%
30	0.026	0.090%	--	--	--	--	0.5%
31	0.043	0.146%	--	--	--	--	0.6%
32	0.012	0.039%	--	--	--	--	0.5%
33	0.030	0.101%	--	--	--	--	0.6%
THD	4.182		--		--		5%

Model: SNA PRO-EU 6.5K

Harmonic	fundamen tal L1 (A)	% of fundamen tal)	fundamen tal L2 (A)	% of fundamen tal)	fundamen tal L3 (A)	% of fundamen tal)	Harmonic Current Limits (%)
02	0.109	0.387%	--	--	--	--	1.0%

03	0.412	1.459%	--	--	--	--	4.0%
04	0.153	0.543%	--	--	--	--	1.0%
05	0.121	0.427%	--	--	--	--	4.0%
06	0.045	0.160%	--	--	--	--	1.0%
07	0.042	0.149%	--	--	--	--	4.0%
08	0.071	0.250%	--	--	--	--	1.0%
09	0.090	0.319%	--	--	--	--	4.0%
10	0.011	0.040%	--	--	--	--	0.5%
11	0.051	0.179%	--	--	--	--	2.0%
12	0.029	0.103%	--	--	--	--	0.5%
13	0.087	0.309%	--	--	--	--	2.0%
14	0.049	0.173%	--	--	--	--	0.5%
15	0.067	0.237%	--	--	--	--	2.0%
16	0.011	0.041%	--	--	--	--	0.5%
17	0.034	0.122%	--	--	--	--	1.5%
18	0.044	0.156%	--	--	--	--	0.5%
19	0.087	0.309%	--	--	--	--	1.5%
20	0.054	0.191%	--	--	--	--	0.5%
21	0.029	0.103%	--	--	--	--	1.5%
22	0.025	0.089%	--	--	--	--	0.5%
23	0.022	0.076%	--	--	--	--	0.6%
24	0.053	0.187%	--	--	--	--	0.5%
25	0.069	0.245%	--	--	--	--	0.6%
26	0.063	0.224%	--	--	--	--	0.5%
27	0.014	0.050%	--	--	--	--	0.6%
28	0.021	0.076%	--	--	--	--	0.5%
29	0.035	0.125%	--	--	--	--	0.6%
30	0.046	0.162%	--	--	--	--	0.5%
31	0.046	0.162%	--	--	--	--	0.6%
32	0.021	0.076%	--	--	--	--	0.5%
33	0.023	0.080%	--	--	--	--	0.6%
THD	2.199%		--		--		5%
Supplementary information: Test with 230 Va.c.							

4.7		TABLE: Power factor						P
Model: SNA PRO-EU 3K								
	Input			Output				
No	Voltage (V d.c.)	Current (A d.c.)	Power (W)	Voltage (V a.c.)	Current (A a.c.)	Power (W)	Power factor (+/-)	Rated output (V.A)
1	374.42	2.02	526.32	219.92	2.93	604.42	0.9884	(20±5)%
2	374.41	2.90	857.26	219.93	4.25	908.53	0.9727	(30±5)%
3	374.41	3.59	1187.37	219.94	5.60	1212.49	0.9846	(40±5)%
4	374.40	4.58	1532.64	219.95	6.97	1517.42	0.9897	(50±5)%
5	374.34	5.46	1880.14	219.96	8.34	1821.40	0.9926	(60±5)%
6	374.32	6.23	2218.29	219.98	9.72	2125.36	0.9945	(70±5)%
7	374.29	6.96	2549.42	219.99	11.09	2428.65	0.9958	(80±5)%
8	372.74	7.80	2874.02	220.00	12.46	2731.41	0.9967	(90±5)%
9	371.38	8.57	3155.33	220.01	13.59	2981.61	0.9972	(100±5)%
Model: SNA PRO-EU 6.5K								
	Input			Output				
No	Voltage (V d.c.)	Current (A d.c.)	Power (W)	Voltage (V a.c.)	Current (A a.c.)	Power (W)	Power factor (+/-)	Rated output (V.A)
1	370.67	3.34	1228.89	219.94	6.05	1312.56	0.9863	(20±5)%
2	368.93	5.23	1908.56	219.97	9.02	1970.72	0.9936	(30±5)%
3	368.46	7.39	2646.51	219.99	11.99	2627.46	0.9958	(40±5)%
4	371.33	9.42	3492.97	220.02	14.97	3282.53	0.9968	(50±5)%
5	368.18	11.76	4289.20	220.04	17.95	3939.33	0.9974	(60±5)%
6	368.48	14.91	5481.57	220.07	21.05	4623.05	0.9979	(70±5)%
7	364.18	17.41	6320.22	220.09	23.90	5251.80	0.9983	(80±5)%
8	361.40	19.31	6958.19	220.11	26.88	5907.64	0.9986	(90±5)%
9	351.60	19.61	6887.29	220.14	29.61	6509.20	0.9987	(100±5)%
Supplementary information: Test with 220 Va.c. Power factor with “+” indicating leading and “-“ indicating lagging.								

4.7		TABLE: Power factor							P
Model: SNA PRO-EU 3K									
Input			Output						
No	Voltage (V d.c.)	Current (A d.c.)	Power (W)	Voltage (V a.c.)	Current (A a.c.)	Power (W)	Power factor (+/-)	Rated output (V.A)	
1	369.71	1.97	500.61	229.91	2.82	603.84	0.9805	(20±5)%	
2	368.89	2.63	814.05	229.92	4.08	908.59	0.9682	(30±5)%	
3	368.42	3.39	1126.22	229.94	5.37	1212.54	0.9820	(40±5)%	
4	369.00	4.01	1439.99	229.95	6.68	1517.36	0.9879	(50±5)%	
5	367.95	4.94	1754.56	229.96	7.99	1821.66	0.9913	(60±5)%	
6	366.61	5.85	2072.12	229.97	9.30	2125.14	0.9936	(70±5)%	
7	365.23	6.78	2387.88	229.98	10.61	2428.26	0.9950	(80±5)%	
8	365.25	7.54	2697.80	229.99	11.92	2731.68	0.9961	(90±5)%	
9	364.42	8.30	2978.22	230.00	13.10	3002.99	0.9967	(100±5)%	
Model: SNA PRO-EU 6.5K									
Input			Output						
No	Voltage (V d.c.)	Current (A d.c.)	Power (W)	Voltage (V a.c.)	Current (A a.c.)	Power (W)	Power factor (+/-)	Rated output (V.A)	
1	345.20	19.31	6653.41	230.11	28.24	6490.46	0.9986	(20±5)%	
2	348.35	17.51	6025.46	230.09	25.68	5899.72	0.9984	(30±5)%	
3	351.61	15.50	5337.46	230.07	22.85	5247.73	0.9981	(40±5)%	
4	354.88	13.45	4643.17	230.05	20.01	4593.20	0.9977	(50±5)%	
5	359.81	11.17	3955.88	230.03	17.17	3937.70	0.9970	(60±5)%	
6	362.02	9.27	3270.37	230.00	14.32	3282.49	0.9964	(70±5)%	
7	365.03	7.24	2587.02	229.98	11.48	2626.82	0.9952	(80±5)%	
8	367.93	5.29	1912.47	229.96	8.64	1970.95	0.9925	(90±5)%	
9	369.08	3.51	1233.55	229.93	5.80	1311.88	0.9832	(100±5)%	
Supplementary information: Test with 230 Va.c. Power factor with "+" indicating leading and "-" indicating lagging.									

5.2.1 & 5.4		TABLE: Under-and over-voltage trip settings and reconnection test						P
(1) Under voltage disconnection procedure								
Rated output voltage (V)	Output power (VA)	Required min. voltage (V)	Value of PCE trip settings (V)	Ratio of decreased (V / s)	Interval time (s)	Measured tripped voltage (V)	Measured disconnection time (s)	
220	6500	187	187	0.1	2	188	1.955	
Rated output voltage (V)	Output power (VA)	Required min. voltage (V)	Value of PCE trip settings (V)	Ratio of decreased (V / s)	Interval time (s)	Measured tripped voltage (V)	Measured disconnection time (s)	
220	6500	110	110	0.1	1	110	0.067	
(2) Under voltage reconnection procedure								
Ratio of voltage rapidly decreased (V / s)			Reconnection voltage (V)		Reconnection time (s)			
0.1			>187		62			
(3) Over voltage disconnection procedure								
Rated output voltage (V)	Output power (VA)	Required max. voltage (V)	Value of PCE trip settings (V)	Ratio of increased (V / s)	Interval time (s)	Measured tripped voltage (V)	Measured disconnection time (s)	
220	6500	242	242	0.1	2	240	1.959	
Rated output voltage (V)	Output power (VA)	Required max. voltage (V)	Value of PCE trip settings (V)	Ratio of increased (V / s)	Interval time (s)	Measured tripped voltage (V)	Measured disconnection time (s)	
220	6500	297	297	0.1	0.05	297	0.038	
(4) Over voltage reconnection procedure								
Ratio of voltage rapidly decreased (V / s)			Reconnection voltage (V)		Reconnection time (s)			
0.1			<242		62			
Supplementary information: Tested on model SNA PRO-EU 6.5K								

5.2.1 & 5.4		TABLE: Under-and over-voltage trip settings and reconnection test						P
(1) Under voltage disconnection procedure								
Rated output voltage (V)	Output power (VA)	Required min. voltage (V)	Value of PCE trip settings (V)	Ratio of decreased (V / s)	Interval time (s)	Measured tripped voltage (V)	Measured disconnection time (s)	
230	6500	195.5	195.5	0.1	2	196	1.965	
Rated output voltage (V)	Output power (VA)	Required min. voltage (V)	Value of PCE trip settings (V)	Ratio of decreased (V / s)	Interval time (s)	Measured tripped voltage (V)	Measured disconnection time (s)	

230	6500	115	115	0.1	0.1	115	0.071
(2) Under voltage reconnection procedure							
Ratio of voltage rapidly decreased (V / s)			Reconnection voltage (V)			Reconnection time (s)	
0.1			>195.5			62	
(3) Over voltage disconnection procedure							
Rated output voltage (V)	Output power (VA)	Required max. voltage (V)	Value of PCE trip settings (V)	Ratio of increased (V / s)	Interval time (s)	Measured tripped voltage (V)	Measured disconnection time (s)
230	6500	253	253	0.1	2	253	1.967
Rated output voltage (V)	Output power (VA)	Required max. voltage (V)	Value of PCE trip settings (V)	Ratio of increased (V / s)	Interval time (s)	Measured tripped voltage (V)	Measured disconnection time (s)
230	6500	299	299	0.1	0.05	298	0.010
(4) Over voltage reconnection procedure							
Ratio of voltage rapidly decreased (V / s)			Reconnection voltage (V)			Reconnection time (s)	
0.1			<242			62	
Supplementary information: Tested on model SNA PRO-EU 6.5K							

5.2.2 & 5.4		TABLE: Over/under frequency trip settings and reconnection test						P
(1) Under frequency disconnection procedure								
Rated output frequency (Hz)	Output power (VA)	Required min. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of decreased (Hz / s)	Interval time (s)	Measured tripped frequency (Hz)	Measured disconnection time (s)	
50	6500	49	49	0.01	0.3	49	0.158	
(2) Under frequency reconnection procedure								
Ratio of frequency rapidly decreased (Hz / s)			Reconnection frequency (Hz)		Reconnection time (s)			
0.01			>59		62			
(3) Over frequency disconnection procedure								
Rated output frequency (Hz)	Output power (VA)	Required max. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of increased (Hz / s)	Interval time (s)	Measured tripped frequency (Hz)	Measured disconnection time (s)	
50	6500	51	51	0.01	0.3	50.9	0.159	
(4) Over frequency reconnection procedure								
Ratio of frequency rapidly decreased (Hz / s)			Reconnection frequency (Hz)		Reconnection time (s)			
0.01			<51		62			
Supplementary information: Tested on model SNA PRO-EU 6.5K								


5.2.2 & 5.4		TABLE: Over/under frequency trip settings and reconnection test						P
(1) Under frequency disconnection procedure								
Rated output frequency (Hz)	Output power (VA)	Required min. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of decreased (Hz / s)	Interval time (s)	Measured tripped frequency (Hz)	Measured disconnection time (s)	
60	6500	59	59	0.01	0.3	59	0.131	
(2) Under frequency reconnection procedure								
Ratio of frequency rapidly decreased (Hz / s)			Reconnection frequency (Hz)		Reconnection time (s)			
0.01			>59		62			
(3) Over frequency disconnection procedure								
Rated output frequency (Hz)	Output power (VA)	Required max. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of increased (Hz / s)	Interval time (s)	Measured tripped frequency (Hz)	Measured disconnection time (s)	
61	6500	51	61	0.01	0.3	61	0.142	
(4) Over frequency reconnection procedure								

Ratio of frequency rapidly decreased (Hz / s)	Reconnection frequency (Hz)	Reconnection time (s)
0.01	<51	62
Supplementary information: Tested on model SNA PRO-EU 6.5K		

Appendix 1: Photos



Overview



Bottom view

Appendix 1: Photos



Connection view



Internal view

--- End of test report---