

Certificate of Conformity

Certificate Number: CN-PVES-260009


On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Shenzhen Lux Power Technology Co., Ltd. C501, Building A, Donghua Industrial Park, 5003 Bao'an Avenue, Sanwei Community, Hangcheng Street, Bao'an District, Shenzhen, 518126, China.
Product:	Energy Storage Inverter
Ratings & Principle Characteristics:	See appendix of Certificate of Conformity
Model:	SNA PRO-EU 3K, SNA PRO-EU 4K, SNA PRO-EU 5K, SNA PRO-EU 6K, SNA PRO-EU 6.5K
Brand Name<s>:	Lux Power
Product Complies with:	NRS 097-2-1:2024 GRID INTERCONNECTION OF EMBEDDED GENERATION PART 2: SMALL-SCALE EMBEDDED GENERATION SECTION 1: UTILITY INTERFACE
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2 nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
Test Report No.<s>:	251027006GZU-001, 06 Jan 2026

Additional information in Appendix.

Signature

Certification Manager: Grady Ye
Date: 09 Jan 2026



01886

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-260009.

Model	SNA PRO- EU 3K	SNA PRO- EU 4K	SNA PRO-EU 5K	SNA PRO-EU 6K	SNA PRO-EU 6.5K
Input (PV)					
Max. input voltage	500 Vd.c.				
MPPT voltage range	80-400 Vd.c.				
Max. short-circuit current	25/25 Ad.c.				
Max. input current per MPPT	20/20 Ad.c.				
Output/Input(Battery)					
Battery type	Lithium-ion/Lead-Acid				
Battery voltage range	38.4-60 Vd.c.				
Max. charge /discharge current	70 Ad.c.	90 Ad.c.	110 Ad.c.	135 Ad.c.	135/140 Ad.c.
Max. charge /discharge current power	3000 W	4000 W	5000 W	6000 W	6500 W
Output/Input (On Grid)					
Rated output power	3000 W	4000 W	5000 W	6000 W	6500 W
Rated input power	6000 W	8000 W	8000 W	9000 W	9000 W
Max. apparent power	3000 W	4000 W	5000 W	6000 W	6500 W
Rated output voltage	230 Va.c., L/N/PE				
Max. output current	13 Aa.c.	17.5 Aa.c.	22 Aa.c.	26.5 Aa.c.	28.2 Aa.c.
Max. input current	26 Aa.c.	35 Aa.c.	35 Aa.c.	39.1 Aa.c.	39.1 Aa.c.
Rated AC grid frequency	50 Hz				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-260009.

Adjustable power factor	0.9 leading-0.9 lagging				
Backup parameter (AC)					
Rated output power	2000 W	2000 W	2000 W	3000 W	3000 W
Max. output current	8.6 Aa.c.	8.6 Aa.c.	8.6 Aa.c.	13 Aa.c.	13 Aa.c.
Rated output voltage	230 Va.c., L/N/PE				
AC frequency	50 Hz				
General Data					
Safety level	Class I				
Degree of protection	IP65				
Operating temperature range	-25~60 °C (derating at 45°C)				
Software Version	CHAA-xx02				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.